

Rugby Environmental Inc

1213 Deer Hill Drive
Wilmington, North Carolina 28409

Phone/Fax (540) 353-0961

November 27, 2023

City of Salem, Virginia
Attention: Mr. Todd Sutphin-Assistant Director Streets/General Maintenance
Salem, Virginia

Re: Pre-Renovation Asbestos Inspection
Salem Circuit Court
Salem, Virginia 24153

Dear Mr. Sutphin:

The following is a summary of the November 21, 2023 Pre-Renovation Asbestos Inspection of three areas within the Salem Circuit Court located at 2 Calhoun Street in Salem, Virginia. This inspection was targeted to Conference Room 5, Jury Room 1, and partial Hallway adjacent to these areas. An Asbestos Survey of the entire facility was beyond the scope of this assignment.

An Asbestos Survey was conducted at the above address on November 21, 2023. The survey was authorized by Mr. Todd Sutphin of the City of Salem, VA. The purpose of this assessment was to identify asbestos containing (ACMs) that may exist in the three areas notated above prior to renovation activities. A material is defined by (EPA) to be asbestos containing if greater than 1% asbestos by weight is detected in the sample.

The survey was conducted on November 21, 2023 by Perry Pence, VA Asbestos Inspector No: 3309 003019. Building components which are generally known to contain asbestos were identified, and, where appropriate, sampled for and transported to the laboratory for analysis. Suspect materials are typically grouped into two categories: friable (able to be crushed and pulverized by hand pressure) and non-friable. Additionally, those materials which are typically non-friable in their normal usage, such as floor tile, may be considered potentially friable. This means that they may be subjected to mechanical abrasion activities (e.g., floor sanding and grinding) which may cause them to become friable. Such suspect materials and their typical application are identified in the EPA document entitled, "Guidance for Controlling Asbestos-Containing Materials in Buildings, 1985 Edition."

During the inspection of the space, suspect asbestos containing materials were inspected and sampled according to homogeneous area. A material or area is considered homogeneous if consistent in size, texture, color, and application. All samples were taken in a randomly distributed manner, in areas of easy access, and in quantity according with EPA Regulations. A total of 28 samples were obtained for analysis from the three areas of the structure and sent to the laboratory for analysis.

These samples were further subdivided into 39 total samples at the Laboratory because of layering.

Each sample was individually sealed in plastic bags and submitted to AmeriSci Laboratory located in Midlothian, Virginia for analysis. AmeriSci is accredited by the National Institute of Standards and Technology (NIST) for polarized light microscopy (PLM) analysis of bulk materials under the National Voluntary Laboratory Accreditation Program (NVLAP). Samples were analyzed with dispersion staining techniques (EPA Interim Method for Determination of Asbestos in Bulk Materials, EPA-600/M4-822-020).

OSHA defines *asbestos containing materials* (ACM) as those materials containing asbestos greater than one percent by weight as measured by laboratory analysis. The following materials listed below tested positive for Asbestos Content. **A copy of the laboratory results is included as part of this report.**


1. **Samples 1121-13 and 1121-14 Tested Positive for Asbestos in the amount of 3% Chrysotile Asbestos. These samples were the Black Floor Tile found within the Jury Room Women's Bathroom. Please note that this material also exists within the Men's Bathroom. These samples are considered non-friable Asbestos and were in fair condition at the time of the survey. There is an estimated 100 square feet of these materials within the Two Bathrooms located in the Jury Room**
2. **Samples 1121-15 and 1121-16 Tested Positive for Asbestos in the amount of 6% Chrysotile Asbestos. These samples was the Black Mastic underneath the Black Floor Tile in the Women's Bathroom. Please note that this material also exists within the Men's Bathroom. These samples are considered non-friable Asbestos and were in Fair condition at the time of the survey. There is an estimated 100 square feet of this material on the within the Two Bathrooms located in the Jury Room.**

All other materials were negative for Asbestos Content,

Please note if additional suspect materials are discovered as a result of renovation or demolition, such materials should be analyzed for asbestos content before being disturbed. All interested parties should field verify any estimated quantities of ACM's before pricing the above work.

Rugby Environmental Inc. is pleased to have had the opportunity to provide these services. Should you have any questions, please do not hesitate to contact me at (540-353-0961).

Cordially,



Perry Pence
Virginia Asbestos Inspector - 3303 003019

ATTACHMENT 1

Laboratory Results



AmeriSci Richmond
13635 GENITO ROAD
MIDLOTHIAN, VIRGINIA 23112
TEL: 8047631200 FAX: 8047631800

November 27, 2023

Rugby Environmental
Attn: Perry Pence
1213 Deer Hill Drive
Wilmington, NC 28409

RE: Rugby Environmental
Job Number 123111779
P.O. #1121-2
1121-2; City Of Salem Court House; Pre-Renovation Asbestos Inspection

Dear Perry Pence:

Enclosed are the results for PLM asbestos analysis of the following Rugby Environmental samples received at AmeriSci on Wednesday, November 22, 2023, for a 24 hour turnaround:

1121-1, 1121-2, 1121-3, 1121-4, 1121-5, 1121-6, 1121-7, 1121-8, 1121-9, 1121-10, 1121-11, 1121-12, 1121-13, 1121-14, 1121-15, 1121-16, 1121-17, 1121-18, 1121-19, 1121-20, 1121-21, 1121-22, 1121-23, 1121-24, 1121-25, 1121-26, 1121-27, 1121-28

The 28 samples contained in zip lock bag were shipped to AmeriSci via Fed Ex 8175 6325 8636 B 1005. These samples were prepared and analyzed according to EPA PLM Method (EPA 600/R-93/116 Section 2.2). The required analytical information, analysis results, analyst signature and laboratory identification are contained in the PLM Bulk Asbestos Report. If TEM analysis was requested for selected samples the gravimetric reduction data (by Sec 2.3) and TEM Asbestos % (by Sec 2.5) are included in Table 1 along with a summary of Asbestos % by PLM for all samples analyzed.

This report relates ONLY to the sample analysis expressed as % asbestos. AmeriSci assumes no responsibility for customer supplied data such as "sample type", "location", or "area sampled". This report must not be used to claim product endorsement by AmeriSci, NVLAP or any agency of the U. S. Government. The National Institute of Standards and Technology accreditation requirements mandate that this report must not be reproduced, except in full, without the written approval of the laboratory. This report may contain specific data not covered by NVLAP or ELAP accreditations, if so identified in relevant footnotes.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "G. Massey". The signature is fluid and cursive, with a long horizontal stroke at the end.

Glenn F. Massey
QA Manager | Authorized Signatory

Boston - Los Angeles - New York - Richmond

**AmeriSci Richmond**

13635 GENITO ROAD
MIDLOTHIAN, VIRGINIA 23112
TEL: (804) 763-1200 • FAX: (804) 763-1800

PLM Bulk Asbestos Report

Rugby Environmental
Attn: Perry Pence
1213 Deer Hill Drive

Wilmington, NC 28409

Date Received 11/22/23 **AmeriSci Job #** 123111779
Date Examined 11/27/23 **P.O. #**
Page 1 of 7

RE: 1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-1	123111779-01L1 Location: Conference Rm 5 - Cove Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Non-Fibrous, Cove Base Asbestos Types: Other Material: Non-fibrous 100%			
1121-1	123111779-01L2 Location: Conference Rm 5 - Cove Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Cream/Brown, Heterogeneous, Non-Fibrous, Mastic Asbestos Types: Other Material: Non-fibrous 100%			
1121-2	123111779-02L1 Location: Conference Rm 5 - Cove Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Non-Fibrous, Cove Base Asbestos Types: Other Material: Non-fibrous 100%			
1121-2	123111779-02L2 Location: Conference Rm 5 - Cove Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Cream/Brown, Heterogeneous, Non-Fibrous, Mastic Asbestos Types: Other Material: Non-fibrous 100%			
1121-3	123111779-03L1 Location: Conference Rm 5 - Carpet & Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Blue, Heterogeneous, Fibrous, Carpet Asbestos Types: Other Material: Synthetic fibers 80%, Non-fibrous 20%			

See Reporting notes on last page

Client Name: Rugby Environmental

PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-3	123111779-03L2 Location: Conference Rm 5 - Carpet & Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Yellow, Heterogeneous, Non-Fibrous, Glue Asbestos Types: Other Material: Non-fibrous 100%			
1121-4	123111779-04L1 Location: Conference Rm 5 - Carpet & Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Blue, Heterogeneous, Fibrous, Carpet Asbestos Types: Other Material: Synthetic fibers 80%, Non-fibrous 20%			
1121-4	123111779-04L2 Location: Conference Rm 5 - Carpet & Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Yellow, Heterogeneous, Non-Fibrous, Glue Asbestos Types: Other Material: Non-fibrous 100%			
1121-5	123111779-05 Location: Conference Room 5 - Wallpaper	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Off-White, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Synthetic fibers 10%, Non-fibrous 90%			
1121-6	123111779-06 Location: Conference Room 5 - Wallpaper	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Off-White, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Synthetic fibers 10%, Non-fibrous 90%			
1121-7	123111779-07.1 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White/Brown, Heterogeneous, Non-Fibrous, Drywall Asbestos Types: Other Material: Cellulose 3.0%, Non-fibrous 97%			

See Reporting notes on last page

Client Name: Rugby Environmental

PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-7	123111779-07.2 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White, Heterogeneous, Non-Fibrous, Joint Compound Asbestos Types: Other Material: Non-fibrous 100%			
1121-8	123111779-08.1 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White/Brown, Heterogeneous, Non-Fibrous, Drywall Asbestos Types: Other Material: Cellulose 3.0%, Non-fibrous 97%			
1121-8	123111779-08.2 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White, Heterogeneous, Non-Fibrous, Joint Compound Asbestos Types: Other Material: Non-fibrous 100%			
1121-9	123111779-09.1 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White/Brown, Heterogeneous, Non-Fibrous, Drywall Asbestos Types: Other Material: Cellulose 3.0%, Non-fibrous 97%			
1121-9	123111779-09.2 Location: Conference Rm 5 Drywall/Joint Comp	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White, Heterogeneous, Non-Fibrous, Joint Compound Asbestos Types: Other Material: Non-fibrous 100%			
1121-10	123111779-10 Location: Conference Rm 5 1x1 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			

See Reporting notes on last page

Client Name: Rugby Environmental

PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-11	12311779-11 Location: Conference Rm 5 1x1 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-12	12311779-12 Location: Conference Rm 5 1x1 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-13	12311779-13 Location: Jury Room Womens Bath FI Tile	Yes	3.0% (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 3.0% Other Material: Non-fibrous 97%			
1121-14	12311779-14 Location: Jury Room Womens Bath FI Tile	Yes	3.0% (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 3.0% Other Material: Non-fibrous 97%			
1121-15	12311779-15 Location: Jury Room Womens Bath/Black Mastic	Yes	6.0% (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 6.0% Other Material: Non-fibrous 94%			
1121-16	12311779-16 Location: Jury Room Womens Bath/Black Mastic	Yes	6.0% (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Chrysotile 6.0% Other Material: Non-fibrous 94%			

See Reporting notes on last page

Client Name: Rugby Environmental

PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-17	123111779-17L1 Location: Jury Room Black Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Cove Base Asbestos Types: Other Material: Non-fibrous 100%			
1121-17	123111779-17L2 Location: Jury Room Black Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Brown, Heterogeneous, Non-Fibrous, Mastic Asbestos Types: Other Material: Non-fibrous 100%			
1121-18	123111779-18L1 Location: Jury Room Black Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Black, Heterogeneous, Non-Fibrous, Cove Base Asbestos Types: Other Material: Non-fibrous 100%			
1121-18	123111779-18L2 Location: Jury Room Black Base/Mastic	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Brown, Heterogeneous, Non-Fibrous, Mastic Asbestos Types: Other Material: Non-fibrous 100%			
1121-19	123111779-19L1 Location: Jury Room Blue Carpet/Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Blue, Heterogeneous, Fibrous, Carpet Asbestos Types: Other Material: Cellulose 10%, Synthetic fibers 75%, Non-fibrous 15%			
1121-19	123111779-19L2 Location: Jury Room Blue Carpet/Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Yellow, Heterogeneous, Non-Fibrous, Glue Asbestos Types: Other Material: Non-fibrous 100%			

See Reporting notes on last page

Client Name: Rugby Environmental

PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-20	123111779-20L1 Location: Jury Room Blue Carpet/Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Blue, Heterogeneous, Fibrous, Carpet Asbestos Types: Other Material: Cellulose 10%, Synthetic fibers 75%, Non-fibrous 15%			
1121-20	123111779-20L2 Location: Jury Room Blue Carpet/Glue	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Yellow, Heterogeneous, Non-Fibrous, Glue Asbestos Types: Other Material: Non-fibrous 100%			
1121-21	123111779-21 Location: Jury Room 1 2x4 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-22	123111779-22 Location: Jury Room 1 2x4 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-23	123111779-23 Location: Jury Room 1 2x4 Ceiling Tile	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-24	123111779-24 Location: Jury Rm Ceiling Insulation	No	NAD (by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 100%			

See Reporting notes on last page

Client Name: Rugby Environmental


PLM Bulk Asbestos Report1121-2; City Of Salem Court House; Pre-Renovation Asbestos
Inspection

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1121-25	123111779-25	No	NAD
Location: Jury Rm Ceiling Insulation			(by CVES) by William M. Dunstan on 11/27/23
Analyst Description: White, Heterogeneous, Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Fibrous glass 100%			
1121-26	123111779-26	No	NAD
Location: Jury Rm Womens Bath 2x4 Ceiling Tile			(by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-27	123111779-27	No	NAD
Location: Jury Rm Womens Bath 2x4 Ceiling Tile			(by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			
1121-28	123111779-28	No	NAD
Location: Jury Rm Womens Bath 2x4 Ceiling Tile			(by CVES) by William M. Dunstan on 11/27/23
Analyst Description: Gray, Heterogeneous, Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Cellulose 40%, Fibrous glass 20%, Non-fibrous 40%			


Reporting Notes:

Analyzed by: William M. Dunstan

Date: 11/27/2023



Reviewed by: William M. Dunstan



*NAD = no asbestos detected, Detection Limit <1%, Reporting Limits: CVES = 1%, 400 Pt Ct = 0.25%, 1000 Pt Ct = 0.1%; "Present" or NVA = "No Visible Asbestos" are observations made during a qualitative analysis; NA = not analyzed; NA/PS = not analyzed / positive stop; PLM Bulk Asbestos Analysis using Olympus, Model BH-2 microscope, Serial #233533, by EPA 600/R-93/116 per 40 CFR 763 (NVLAP Lab Code 101904-0) and ELAP PLM Analysis Protocol 198.1 for New York friable samples which includes quantitation of any vermiculite observed (198.6 for NOB samples) or EPA 400 pt ct by EPA 600/M4-82-020 (NYSDOH ELAP Lab # 10984); CA ELAP Lab # 2508; Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar NOB materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (also see EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). NIST Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the laboratory. This PLM report relates ONLY to the items tested.

Page 1 of 2

AMERISCI

Environmental Laboratories

CHAIN OF CUSTODY RECORD

AMERISCI
RICHMOND
Job No.:

123111779

AMERISCI RICHMOND
13635 GENITO ROAD
MIDLOTHIAN, VA 23112
PHONE: (804) 763-1200
FAX: (804) 763-1800
TOLL FREE: (800) 476-5227
www.AmeriSci.com

Company Rugby Environ.		Address 1213 Deer Hill Drive		P.O.#:		SPECIAL INSTRUCTIONS:				
PROJECT INFORMATION		ANALYSIS TYPE		TURNAROUND TIME (X)				AIR FILTER INFORMATION:		
				RUSH	6-10 HR	24 HR	48 HR	72 HR	5 DAY	OTHER
JOB NAME: <i>City of Seckm Court house</i>		TEM / AHERA								
JOB No.: <i>1121-2</i>		TEM BULK								
		PLM				X				
		PCM								
JOB MANAGER: <i>Perry Pence</i>		NY ELAP		CALL						
		LEAD		CALL	CALL					
JOB DESCRIPTION: <i>Pre-Renovation Asbestos Inspection</i>		RCRA METAS		CALL	CALL					
		TCLP		CALL	CALL					
		OTHER:								
RESULTS TO: <i>Perry Pence</i>				State Samples Collected: <i>VA</i>						
EMAIL RESULTS? <input checked="" type="checkbox"/> Email:				PHONE: <i>540-353-0961</i>						
WRITTEN REPORT TO: <i>Perry Pence</i>				FAX Results? <input type="checkbox"/> Fax#:						
COMMENTS:				CELL:						
E-Mail Results										
LAB ID	SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X	LITERS / MIN.	TOTAL VOLUME	DATE COLLECTED		
	<i>1121-1</i>	<i>Conference Rm 5 - Cove Base/Mastic</i>						<i>11/21/23</i>		
	<i>1121-2</i>	<i>Conference Rm 5 - Carpet & Glue</i>								
	<i>1121-3</i>	<i>Conference Rm 5 - Carpet & Glue</i>								
	<i>1121-4</i>	<i>Conference Rm 5 - Wallpaper</i>								
	<i>1121-5</i>	<i>Conference Rm 5 - Wallpaper</i>								
	<i>1121-6</i>	<i>Conference Rm 5 - Drywall / Joint Comp.</i>								
	<i>1121-7</i>	<i>Conference Rm 5 - Drywall / Joint Comp.</i>								
	<i>1121-8</i>	<i>Conference Rm 5 - Drywall / Joint Comp.</i>								
	<i>1121-9</i>	<i>Conference Rm 5 - Drywall / Joint Comp.</i>								
	<i>1121-10</i>	<i>Conference Rm 5 - 1X1 Ceiling Tile</i>								
	<i>1121-11</i>	<i>Conference Rm 5 - 1X1 Ceiling Tile</i>								
	<i>1121-12</i>	<i>Conference Rm 5 - 1X1 Ceiling Tile</i>								
	<i>1121-13</i>	<i>Jury Room - Womens Bath Floor Tile</i>								
	<i>1121-14</i>	<i>Jury Room - Womens Bath Floor Tile</i>								
	<i>1121-15</i>	<i>Jury Room - Womens Bath / Black Mastic</i>								
	<i>1121-16</i>	<i>Jury Room - Black Base / Mastic</i>								
	<i>1121-17</i>	<i>Jury Room - Black Base / Mastic</i>								
	<i>1121-18</i>	<i>Jury Room - Blue Carpet / Glue</i>								
	<i>1121-19</i>	<i>Jury Room - Blue Carpet / Glue</i>								
	<i>1121-20</i>	<i>Jury Room - 2x4 Ceiling Tile</i>								
	<i>1121-21</i>	<i>Jury Room - 2x4 Ceiling Tile</i>								
	<i>1121-22</i>	<i>Jury Room - 2x4 Ceiling Tile</i>								
	<i>1121-23</i>	<i>Jury Room - 2x4 Ceiling Tile</i>								
SAMPLED BY: <i>Perry Pence</i>			DATE/TIME: <i>11/21/23</i>	RECEIVED BY: <i>Received</i>			DATE/TIME:			
RELINQUISHED BY: <i>Perry Pence</i>			DATE/TIME: <i>11/21/23</i>	RECEIVED IN LAB BY: <i>NOV 22 2023</i>			DATE/TIME:			

www.AmeriSci.co

Company		Address		P.O.#:					
Rugby Environ.		1213 Deer Hill Drive		SPECIAL INSTRUCTIONS:					
PROJECT INFORMATION		ANALYSIS TYPE	TURNAROUND TIME (X)						AIR FILTER INFORMATION:
JOB NAME: City of Salem Courthouse, VA	TEM/AHERA	RUSH	6-10 Hr	24 Hr	48 Hr	72 Hr	5 DAY	OTHER	MCE
JOB No.: 1121-2	TEM/BULK								PC
JOB MANAGER: Perry Pence	PLM			X					25 mm
JOB DESCRIPTION:	PCM								37 mm
	NY ELAP	CALL							0.45 um
	LEAD	CALL	CALL						0.80 um
	RCRA METAS	CALL	CALL						OTHER:
	TCLP	CALL	CALL						
	OTHER:								
RESULTS TO: Perry Pence					State Samples Collected: VA				
EMAIL RESULTS? Y <input checked="" type="checkbox"/> Email:					PHONE: 540-353-0961				
WRITTEN REPORT TO: Perry Pence					FAX Results? Y <input type="checkbox"/> Fax#:				
COMMENTS: E-Mail Results					CELL:				
LAB ID	SAMPLE ID	SAMPLE LOCATION	START TIME	STOP TIME	TOTAL TIME X LITERS / MIN. = TOTAL VOLUME	DATE COLLECTED			
	1121-24	Jury Rm - Ceiling Insulation				11/21/23			
	1121-25								
	1121-26	Jury Rm Women's Bath 2x4 Ceiling Tile							
	1121-27								
	1121-28								
SAMPLED BY: Perry Pence		DATE/TIME: 11/21/23		RECEIVED BY:		NOV 22 2023		DATE/TIME:	
RELINQUISHED BY: Perry Pence		DATE/TIME: 11/21/23		RECEIVED IN LAB BY:		ALL		DATE/TIME:	

ATTACHMENT 2

Virginia Asbestos Inspector License

COMMONWEALTH of VIRGINIA

Department of Professional and Occupational Regulation

9960 Mayland Drive, Suite 400, Richmond, VA 23233

Telephone: (804) 367-8500

EXPIRES ON

11-30-2023

NUMBER

3303003019

BOARD FOR ASBESTOS, LEAD, AND HOME INSPECTORS
ASBESTOS INSPECTOR LICENSE



PERRY LEE PENCE
1213 DEER HILL DRIVE
WILMINGTON, NC 28409

DPOR

Demetris J. Mello
Demetris J. Mello, Director

Status can be verified at <http://www.dpor.virginia.gov>

(SEE REVERSE SIDE FOR PRIVILEGES AND INSTRUCTIONS)



COMMONWEALTH of VIRGINIA
Department of Professional and Occupational Regulation

BOARD FOR ASBESTOS, LEAD, AND HOME INSPECTORS
ASBESTOS INSPECTOR LICENSE

NUMBER: 3303003019 EXPIRES: 11-30-2023

PERRY LEE PENCE
1213 DEER HILL DRIVE
WILMINGTON, NC 28409



(FOLD)

Status can be verified at <http://www.dpor.virginia.gov>

DPOR-LIC (02/2017)

(DETACH HERE)

DPOR-PC (02/2017)