

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: 434-455-3970

Addendum for Bid
Miller Park Pool Renovations
26-090

Date: July 17, 2026

From: Stephanie Suter, CPPO, CPPB

RE: Addendum No. 4

This Addendum becomes a part of the contract documents and modifies the bid document as noted below. Acknowledge receipt of this addendum in the space provided on the Terms and Signature Sheet. Failure to do so may subject bidder to disqualification.

The bullets below provide information only and no changes to the specifications or drawings from the original bid documents or previously posted addenda.

Questions and Answers:

1. What is the "reused Paver sourced from existing site paving" per L1.20 details 3 & 11? Do you have dimensions of this product? Is this palletized?

These are historic bricks from City Streets. Some are palletized but we have been providing them unpalletized recently on projects without issue. They are not a standard brick size but are approximately 8.5" x 4" x 2.75".

2. Please provide concrete requirements for Pool Fencing F-10. L1.21 says reference civil plans.

Refer to "STANDARD CONCRETE SIDEWALK SECTION" Sheet C0.02.

3. L2.10 indicates 3 cabanas, L1.30 indicates 6, which is correct? If 6 where do the other 3 go onsite?

Three cabanas total associated with Furniture Code L-101.

4. In review of addendum #1 drawings, all of the structural drawings contain a revision 1 as well. This appears to be more than just a notation change of "Bid Set Not for Construction" example being S6.00 and S7.00 now contain a footing schedule. Please indicate all changes on each sheet.

Many changes occurred between the original structural sheet submission and Addendum 1; therefore, the entire sheets were clouded and identified with revision symbol 1 to capture the extent of the updates. Subsequent revisions (2 and 3) have highlighted more specific detailed changes as requested.

5. The survey dwg provided did not provide the existing conditions topo as requested.

The Existing Topo Conditions DWG files are available upon request to stephanie.suter@lynchburgva.gov. Since these files will be sent in a folder, they are not posted to the website.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____